


156250

Illinois



Department of Conservation

life and land together

605 WM. G. STRATTON BUILDING • 400 SOUTH SPRING STREET • SPRINGFIELD 62706
CHICAGO OFFICE - ROOM 100, 160 NO. LASALLE 60601
David Kenney, Director • James C. Helfrich, Assistant Director

March 28, 1979

Mr. James A. Petersen
Chief, Operations Division
Department of the Army
210 North 12th Street
St. Louis, MO 63101

RE: LMSOD-F (Miss. Riv.) P-1323

Dear Mr. Petersen:

We have completed our review of the application by Riverport Terminal and Fleeting Company for a permit authorizing repairs and improvements on and along the left bank of the Mississippi River in St. Clair County, approximate mile 177 to 177.5.

We would not object to the issuance of this permit provided the following items are included in the construction plans:

1. Riprap materials should be limited to concrete and brick only. No dirt or other suspendable fill should be used.
2. Broken concrete used for fill should not contain reinforcement rods since these could become a safety hazard for boats.

Sincerely,

Robert W. Schanzle
Resources Planner
Division of Planning and Design

RWS:th 02-29(79)

cc: Riverport Terminal and Fleeting Co. ✓
Stan Stowers, EPA